

SPECIFICATIONS:
 CONCRETE: 4000 P.S.I @ 28 DAYS.
 ENTRAINED AIR: 5% - 9%
 STEEL: A.S.T.M A496-A615 GRADE 60-60KSI.
 DESIGN LOADING: A-0.3/300PSF/WALKWAYS.
 FLOTATION FORCES NOT ACCOUNTED FOR.

NOTES:
 INLET INVERT IS 2" ABOVE
 OUTLET INVERT. ONE (1) INLET
 & ONE (1) OUTLET BAFFLE
 SUPPLIED. INSTALLED BY G.C.

WEIGHT:
 TOP SECTION: 3,426 LBS.
 BOTTOM SECTION: 11,475 LBS.
 TOTAL: 14,901 LBS.

OUTLET BAFFLE: PIPE BAFFLE BY K.C.P

OPTIONAL ITEMS: EFFLUENT FILTER
 GAS DEFLECTOR

COVER OVER TANK: MAX 3' OF EARTH FILL.

